Ref. Certif. No.

HU-005547

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnector
Name and address of the applicant	Wenzhou Jinhong Electric Co., Ltd. No.10 Yongxing Second Road Chengdong Industrial Functional Zone Yueqing City 325600 Zhejiang, P.R. China
Name and address of the manufacturer	Wenzhou Jinhong Electric Co., Ltd. No.10 Yongxing Second Road Chengdong Industrial Functional Zone Yueqing City 325600 Zhejiang, P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Gorlan Electric (Zhejiang) Co., Ltd. 4/F, Building No. 2, No. 10 Yongxing Second Road, Chengdong Industrial Area, Yueqing City, 325600 Zhejiang, P.R. China
Ratings and principal characteristics	Number of Pole: 3P/3P+N/4P; Ui: 800V; Uimp: 8,0kV; Ith: 40A; Ithe: 40A; AC-23A, AC-22A, AC-21A: Ue: AC415V; Ie: 16/20/25/32/40A; 50/60Hz; Icw: 1,26kA, 1s; Icm=1,8kA; IP20, after installation; IP66, with enclosure
Trademark / Brand (if any)	ZJWZJH KINRED
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	JHAS80-wxz-yk (w=DB, PM, DW, DC, EL or ELA; x=16, 20, 25, 32 or 40; z=blank or R; y=3, 3D or 4; k=blank, BB, BW, RY, FB or FR)
Additional information (if necessary may also be reported on page 2)	N/A
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020 IEC 60947-3:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	CN25OAJM 001

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2025-04-11

Signature: Wencai Zhang

10/061SMD 2024-12 rke-simplified

Disclaimer: This is an electronically released document. The authenticity can be verified on the IECEE Website "http://certificates.iecee.org" (1.3s / 0)